

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 6911-0075:207

Page 1 of 1

CATEGORY: Voice Communication Systems Control Units

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: Brian Reynolds (203) 484-6124 FAX (203) 484-7309

DESIGN: Models ACC-25/50, ACC-25/50ZS, and *ACC-25/50ZST Audio Command Center. These are 25-watt audio emergency voice evacuation panel that provides full supervision of both normal standby and alarm conditions. An optional second audio amplifier is available as a backup to the primary amplifier or to expand speaker power to 50 watts. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

ACC-MCB	Mother Board
ACC-AAM-25	Audio Amplifier
FC-XRM70 (+)	70 V rms Converter Module
FC-LPS (+)	Local Playback Speaker
FC-MIM (+)	Microphone Interface Module
ACC-ZPMK	Zone Page Module w/Keypad
ACC-ZSM	Zone Splitter Module
*FHS-F	Remote Fire Fighter Handset (ACC-25/50ZST Only)
*FPJ-F, *RPJ-F	Remote Phone Jack (ACC-25/50ZST Only)
*ACC-FFT	Fire Fighter Telephone Module (ACC-25/50ZST)

RATING: Primary: 120 V, 60 Hz, 1.57A
Secondary: 24 V dc nominal battery voltage

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label.

APPROVAL: Listed as voice communication systems for use with separately listed compatible fire alarm control units to provide emergency voice evacuation signals. Refer to listee's Installation Instructions Manual for details.

NOTE: For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

*Rev. 03-25-08 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 19, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

